

Comments on the Aurora Application for a LNG Plant Sited at Prince Rupert

Introduction

The proposed Aurora LNG plant will use large gas turbines to generate electrical power as well as to compress natural gas in a gas liquefaction plant. Although the proposed gas turbines will utilize low-emission technology to minimize NOx (oxides of nitrogen) emissions, their combined emissions still have the potential to seriously impact ambient air quality standards and therefore to adversely affect human health in nearby communities. The Interim 2014 BC Ambient Air Quality One-Hour Standard for NO₂ (nitrogen dioxide) is 188 micrograms per cubic meter (mcg/m³) or equivalently, 100 parts per billion (ppb). These values are subject to revision. Ambient NO₂ concentrations above these levels may result in adverse health effects, such as breathing difficulties and increased lung disease.

How ambient NO₂ concentrations are estimated

Ambient NO₂ levels are estimated using computer models developed by the USA Environmental Protection Agency (EPA) and subsequently adopted by the BC Ministry of Environment. These models (AERMOD and CALPUFF) calculate ambient NOx concentrations (mcg/m³), given the NOx emissions from combustion sources, in terms of grams/second NOx. The ambient NOx concentrations are then converted in a post-processor to ambient NO₂ concentrations, which can then be compared to ambient air quality standards. A commonly used Tier 3 NOx post-processor algorithm is the Ozone Limiting Method (OLM). The OLM computes ambient NO₂ from ambient NOx, given the ambient ozone (O₃) concentration and given the fraction of NOx already converted to NO₂ in the stack, before being emitted to the atmosphere. The fraction of NOx conversion, or in-stack ratio (ISR), for NO₂/NOx was traditionally assigned a default value of 0.10, which was typical of many industrial NOx sources (e.g. internal combustion engines, coal-fired power plants, etc.).

However, following an extensive survey of the measured values of ISR for different combustion sources, the EPA is now recommending using a default value of 0.5 for the ISR, unless reliable source-specific ISR data is available, in which case the measured values should be used. (See page 9 of the EPA 2014 report by Owen and Brode https://www3.epa.gov/scram001/guidance/clarification/NO2_Clarification_Memo-20140930.pdf) The estimated value of NO₂ for locations close (i.e. within a few kilometers) of the emission sources is sensitive to the assumed value for the ISR.

Memo – Genesis Engineering Inc., June 5, 2017

The EPA database (https://www3.epa.gov/scram001/no2_isr_database.htm) for measured ISR values includes only a single source for a low-emission gas turbine. It is expected that the ISR value for this gas turbine will be similar to those proposed by Aurora. The ISR values for this low-emission gas turbine were measured under various gas turbine power levels and the results varied from 0.07 to 0.32. The corresponding NOX values did not increase with load as expected, hence the accuracy and reliability of the measurements may be in doubt. However, we will take a value of **0.3** as a reasonable (“best-guess”) value for the ISR for a low-emission gas turbine under full load, and use this to replace the default ISR value of 0.1 that is still used by some modellers in the AERMOD and CALPUFF models. The NO2 modeling estimates made in the Aurora application were done using the traditional ISR default value of 0.10. The next section of this memo will look at the changes to the estimated ambient NO2 concentrations for two sensitive locations when the ISR value is changed from 0.1 (traditional default value) to 0.3 (a measured value).

Revised estimate of ambient NO2 concentrations at two communities located close to the proposed Aurora LNG plant

Two sensitive locations were examined using revised values for the ISR:

1. Central Dodge Cove residential area (D337D in Aurora Appendix R Human Health, p.131)
2. Graham Avenue Childcare in Prince Rupert (between PR259 and PR260 D337D in Aurora Appendix R Human Health, p.104)

For simplicity it was assumed that an ISR value of 0.30 would be applicable to **all** of the Project NOx emissions, instead of just the gas turbine NOx emissions, since some will be combustion sources with a low ISR value whereas others may be more appropriately applied to the EPA recommended default ISR value of 0.50. For Base NOx sources (existing non-project sources) an ISR value of 0.20 is assumed as this is the EPA recommended default ISR value for distant sources (*loc. cit.*).

When ambient NO2 concentration has been estimated, using one of the two models mentioned above, it is difficult to back-calculate what the corresponding ambient NOx concentration would be unless there is only a single source emitting the NOx. In large projects there may be many sources contributing to the existing NOx ambient concentrations (Base case) and many new sources contributing to the Project-related NOx ambient concentrations. The Cumulative case results when all sources are modeled. Note that the Cumulative NOx value will usually not be equal to the sum of the Base and the Project values. This is because the 1-hour weather conditions that result in the maximum group values are different for each of the three groups.

Below we will attempt to estimate revised ambient NO2 values using two different simplified approaches. First we recalculate the Cumulative case NO2 assuming an ISR value of 0.30 for all sources, instead of the traditional value of 0.10. Secondly, we recalculate the NO2 for the Base case using an ISR

Memo – Genesis Engineering Inc., June 5, 2017

value of 0.20 and recalculate the NO₂ for the Project case using an ISR value of 0.30 for all project sources and then add up the two NO₂ concentrations to approximate the Cumulative case NO₂.

1. **Central Dodge Cove residential area.** Here the reported 1-hour Project NO₂ concentration was 106.6 mcg/m³ while the 1-hour Base NO₂ concentration was 43.7 mcg/m³, using an ISR value of 0.10. The Cumulative estimated NO₂ value was 132 mcg/m³.

a) Single-Group Estimate: Using the OLM formula with an ISR of 0.10, ozone 50 ppb and Cumulative NO₂ of 132 mcg/m³ the ambient NO_x is back-calculated to be 477 mcg/m³. Using the OLM with ISR=0.3 we then estimate the ambient NO₂ to be **209 mcg/m³**. This value is well above (111%) of the allowable Standard of 188 mcg/m³.

b) Three-Group Estimate: Using a similar approach as above, the Project-related NO_x is 222.7 mcg/m³ and hence the NO₂ (ISR= 0.3) is 132.3. The reported Base NO₂ of 43.7 mcg/m³ does not change since it was assumed that all of the Base-related NO_x is converted to NO₂ when the NO_x < O₃. Hence an estimate of the total NO₂ is the sum of 132.3 + 43.7 = **176 mcg/m³**. This value is close to (94%) of the allowable maximum value of 188 mcg/m³.

2. **Graham Avenue Childcare in Prince Rupert.** Here the reported 1-hour Project NO₂ concentration was 105.4 mcg/m³ while the 1-hour Base NO₂ concentration was 61.2 mcg/m³, using an ISR value of 0.10. The Cumulative estimated NO₂ value was 134.4 mcg/m³.

a) Single-Group Estimate: The single-group estimate (ISR = 0.3) is **216 mcg/m³**, or 115% of the allowable maximum.

b) Three-Group Estimate: The three-group estimate is **190 mcg/m³**, or 101% of the maximum allowable 1-hour NO₂ concentration.

Conclusions & Recommendations

We have seen that the most recent EPA recommendations for updating the Ozone Limiting Method, which is used for estimating ambient NO₂ from modeled values of NO_x, uses a default ISR (in-stack NO₂/NO_x ratio) value of 0.5 instead of 0.1. This reflects updated knowledge of modern combustion sources which often embody some sort of NO_x control. The EPA also states that measured values of ISR should be used, when available. Measured values for a low-emission gas turbine indicate that an ISR of 0.3 would be an appropriate value.

The ambient NO₂ values at two sensitive receptors (Dodge Cove community and Graham Avenue Childcare Center) were estimated using the revised ISR values and using previously modeled NO₂ values,

Memo – Genesis Engineering Inc., June 5, 2017

which used an ISR value of 0.1. The estimates were carried out using two different, simplified approaches. In each case the estimated maximum NO₂ concentrations at the sensitive receptors either approached or exceeded the allowable maximum NO₂ concentrations.

In light of this result it is highly recommended that the modeling be redone, using the revised values for the ISR, and if the modeling results continue to demonstrate high NO₂ levels at sensitive locations, that the LNG plant proponent find ways to reduce NOx emissions from the plant.